

**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Claude Rancourt
Company: OCWA - SRF - Fauquier WTP
Address: 70 First Ave, Box 160
Smooth Rock Falls, ON, P0L 2B0
Phone: (705) 362-8481
Email: crancourt@ocwa.com
Sampled By: Rod Blake

Work Order Number: 431185
PO #: 18164
Regulation: O.Reg. 170
Project #: Org. # 5312
Fax: (705) 362-4684
DWS #: 210000979

Date Order Received: 5/26/2021
Arrival Temperature: 11 °C

Analysis Started: 5/26/2021
Analysis Completed: 5/28/2021

TEST RESULTS

Sample Description	Lab ID	Type / Matrix	Date / Time Collected	Field Chlorine		EC	TC	HPC
				Free	Combined			
F-1 Raw Water (Groundhog River) *	1646708	Raw / Raw Water	5/25/2021 11:15 AM			10*	50*	
F-2 Treated Water	1646709	Entry / Treated Water	5/25/2021 11:15 AM		2.14	0	0	<10
F-3 25 Grzela Road	1646710	Distribution / Treated Water	5/25/2021 10:30 AM		1.77	0	0	
F-4 Hwy 11 Bleeder	1646711	Distribution / Treated Water	5/25/2021 10:00 AM		1.6	0	0	<10

Result Units: CFU/100mL (water matrix) CFU/g (soil matrix), CFU/Swab (swab sample), except HPC which is CFU/1mL. Temp. is in Degrees Celsius.

Note that all tests have been performed in accordance with our accredited and licensed test methods (Method Reference A10 for E. coli, fecal, total coliform and background, and Method Reference A68 for HPC).

* Sample required dilution, please refer to the accompanying spreadsheet for sample-specific method detection limits.

REPORT COMMENTS

Bacti lot#2009

This report has been approved by:

Adam Tam, M.Sc.
Laboratory Director

LEGEND

TESTS EC - Escherichia coli, TC - Total Coliforms, FC - Fecal Coliforms, Back - Background, HPC - Heterotrophic Plate Count

RESULTS ~ - No Data. Results Pending.
INT - Interferences are evident on plate and therefore bacterial colonies cannot be properly counted (interferences can be anything that inhibit the proper growth and formation of target colonies)
NDOGN - No Data, Overgrown with Non-Target
NDOGT - No Data, Overgrown with Target
NDOGHPC - No Data. Overgrown with HPC
An 'r' after the Lab ID indicates a laboratory replicate.
An 'rr' after the Lab ID indicates a requested rerun.
Results relate only to the items tested.