

**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

## CERTIFICATE OF ANALYSIS

Client: Bruce Larstone  
Company: OCWA - SRF - Fauquier WTP  
Address: 70 First Ave, Box 160  
Smooth Rock Falls, ON, P0L 2B0  
Phone: (705) 338-4677  
Email: blarstone@ocwa.com  
Sampled By: Rod Blake

Work Order Number: 428051  
PO #: 18164  
Regulation: O.Reg. 170  
Project #: Org. # 5312  
Fax: (705) 338-4586  
DWS #: 210000979

Date Order Received: 4/21/2021  
Arrival Temperature: 14 °C

Analysis Started: 4/21/2021  
Analysis Completed: 4/23/2021

## TEST RESULTS

Sample Description	Lab ID	Type / Matrix	Date / Time Collected	Field Chlorine		EC	TC	HPC
				Free	Combined			
F-1 Raw Water (Groundhog River) *	1634704	Raw / Raw Water	4/21/2021 9:00 AM			<5*	10*	
F-1 Raw Water (Groundhog River) *	1634704[r]	Raw / Raw Water	4/21/2021 9:00 AM			<5*	10*	
F-2 Treated Water	1634705	Entry / Treated Water	4/21/2021 9:00 AM		2.26	0	0	<10
F-3 25 Grzela Road	1634706	Distribution / Treated Water	4/21/2021 8:50 AM		1.9	0	0	<10
F-4 Bleeder	1634707	Distribution / Treated Water	4/21/2021 8:30 AM		1.78	0	0	

Result Units: CFU/100mL (water matrix) CFU/g (soil matrix), CFU/Swab (swab sample), except HPC which is CFU/1mL. Temp. is in Degrees Celsius.

Note that all tests have been performed in accordance with our accredited and licensed test methods (Method Reference A10 for E. coli, fecal, total coliform and background, and Method Reference A68 for HPC).

\* Sample required dilution, please refer to the accompanying spreadsheet for sample-specific method detection limits.

## REPORT COMMENTS

Bacti lot# 2009

This report has been approved by:

Adam Tam, M.Sc.  
Laboratory Director

## LEGEND

TESTS EC - Escherichia coli, TC - Total Coliforms, FC - Fecal Coliforms, Back - Background, HPC - Heterotrophic Plate Count

RESULTS ~ - No Data. Results Pending.  
INT - Interferences are evident on plate and therefore bacterial colonies cannot be properly counted (interferences can be anything that inhibit the proper growth and formation of target colonies)  
NDOGN - No Data, Overgrown with Non-Target  
NDOGT - No Data, Overgrown with Target  
NDOGHPC - No Data. Overgrown with HPC  
An 'r' after the Lab ID indicates a laboratory replicate.  
An 'rr' after the Lab ID indicates a requested rerun.  
Results relate only to the items tested.